



Working on behalf of *love every drop*
anglianwater



Water Regulations Inspection Notice

This notice is served in accordance with the statutory powers of the water undertaker to enforce the Water Supply (Water fittings) Regulations 1999

Job No.	474234	Property Ref.	7885473		Inspection Address
SIC Code	960	Risk ID	Medium	WR	06
Business Type	Cemetery				
Contact Name	Mr J Haste				
Contact Tel No.	01733 252833				
Email address	clerk@glintonparishcouncil.org.uk				
					Mailing Address (if different)
					Glington Parish Council Cemetery Rectory Lane Glington Peterborough PE6 7LR

Type of Inspection	First Inspection	Inspection Status	Failed
Date of 1st inspection <small>(if applicable)</small>		If 'Other' please specify:	

Very High Risk Items Identified							
Borehole(s)				Lead Pipe			
Status	None located	Number of issues		Status	None located	Number of issues	
RPZ Valve(s)				Water Re-use/Rainwater Harvesting Systems			
Status	None located	Number of issues		Status	None located	Number of issues	

Other Items Identified							
Taps with Hose Connection				Supply Pipe(s)			
Status	Failed	Number of issues	1	Status	Passed	Number of issues	
Materials & Fittings				-			
Status	Passed	Number of issues		Status	-	Number of issues	
-				-			
Status	-	Number of issues		Status	-	Number of issues	
-				-			
Status	-	Number of issues		Status	-	Number of issues	
-				-			
Status	-	Number of issues		Status	-	Number of issues	

Inspector Signature	<i>KR Thorpe</i>	Inspector Name	Keith Thorpe
		Inspector Tel No.	07501 225141

For any contraventions/issues found we will formally write to you stating the infringement and the remedial action required

Customer Name		Time	11:30am	1	Issue(s) identified on your premises
Position		Date	23/6/16		

Customer Signature	Comments: Unattended site visit
--------------------	------------------------------------

I, the above signed, confirm that a full inspection of the whole property named above has been carried out and all of the water fittings and supply have been disclosed. I understand and have been clearly informed of my/our responsibilities to ensure that all necessary remedial work is carried out as within the stated timescales.

PLEASE NOTE: Where required we will be re-visiting your site/ premises on the re-inspection date specified. Should this appointment not be convenient you must inform us at least 7 days prior to this date.	Re-inspection Date <small>(if applicable)</small>	1/9/16 11.00am -12.00pm
--	--	----------------------------



Water Regulations Improvement Notice

This notice is served in accordance with the statutory powers of the water undertaker to enforce the Water Supply (Water fittings) Regulations 1999

Job no. 474234

Property Ref. 7885473

Page No. 1

Ref.	12	Issues Identified	Taps with Hose Connection	No. of Issues	1
------	----	-------------------	---------------------------	---------------	---

Description of Issue

All mains fed taps (with a hose connector) on site require appropriate backflow protection.

Photographic Evidence




See details below

Tap with hose connection.

Remedial Action Required

An approved backflow prevention device suitable for fluid category 3 should be installed within the building as the preferred method of protection. This would normally be a double check valve, but a no less effective device or plumbing arrangement may be used. Alternatively an approved backflow prevention device in the form of a tap with built in double check valve can be installed externally where this is not possible (see below for image)



For further information please refer to the 'Water Regulations Guide'

Fluid Category Risk Identified

3

Completion Due Date

22/8/16

There are five fluid categories in which water and fluids can sit. A list is available, upon request, describing the various fluids and types of backflow prevention devices that can be used to prevent backflow, along with the timescale and considerations given to allow implementation of any remedial work required and ensure compliance with the Water Supply (Water fitting) Regulations 1999.